



MEC-TRIC CONTROL COMPANY
411 0 MONROE ROAD
P.O. BOX 221918
CHARLOTTE, N.C. 28222
(704) 376-8555
FAX (704) 375-1728

Control
Number **V/UV** - UV M3-2570-1

Page 1 of 1

Assembly Order

Sold To

Allnex USA Inc.

City State Zip

Cust. Order No.: 4500947948

Ship To

Allnex USA Inc.

131 Revco Road

PO # 4500947948

City State Zip
N Augusta SC 29842

Date Shipped: Shipped Via:

Order Date 9/15/23	Customer ID 02-0010239	Date Req. 9/20/23	Written By RF	Customer Cost Labor Material Total
-----------------------	---------------------------	----------------------	------------------	---------------------------------------

Contact: Email: Phone Number

DESCRIPTION

Model Number Farris 26DA10L-140/S4	Assembled By: AN/CJ	Spring No. E0355SS	Inlet Size 1"	Inlet Connection 150#FLNG	Set Pressure 140 PSIG	Service Liquid
Orifice 0.150 Sq In	Capacity 46 GPM	Spring Range 132-142 PSI	Outlet Size 2"	Outlet Connection 150#FLNG	% 10 O.P.	B.P. 0 PSIG
Serial Number 988681-1-A10	Tagging Instructions 021-PSV-0323	Temp. 72F	Special Instructions			

MATERIAL REQUISITION

Description	MCC-C	Drawn From Stock	Date Ordered
47-26DA10120S3		1	
48-16146X5010		1	
48-3401X11010		1	
N48-303401X11010			9/15/23
N48-E0355SS			9/15/23
N48-4K26140AS4			9/15/23

SHOP

Nameplate Code Stamping

V	UV	NB	NONE (Reason)	
	X	X		
Date			Tester	C.I.
09/21/23			AN/CJ	CJ
Date Completed			Seals	Tag
09/21/23			AN/CJ	AN/CJ
Test Media	Cert. Lift In Inches		Set	B.D.
WATER			140	37
B.P.	Over Pressure		Leak Tight To	
0	14 PSIG		126 PSIG	
Dyn Or Static		DYNAMIC	Gauge No:	
			DPG-7	
Simmer	138		CDTP@ N/A	
Pop	140		B.P. TEST @ N/A	
Reseat	103			
B.D.	37			
Number Of Notches	-4			
Leak	NO			

Internal Use Only	Total=	Time=
IF ORDERED	DATE ORDERED	/ / BY
FILE ORDERED ON		